DAV PUBLIC SCHOOL

(Under direct control of DAV college management committee)

7BLM-A, Srivijaynagar, Anupgarh-335704

Date:-	04/01	/2024
Date.	O_{-1}/O_{-1}	/ _ U _ ¬

Regarding tender number __ RJ008/23A01 _ _ dated _ _ 13/12/2023 _ _ , following are the clarifications in respect to the gueries raised in pre bid meeting.

1. Item no. 31, W.C. specification, in BOQ of construction of new academic block and Item no. 30, W.C. specification, in BOQ of renovation of existing office block, following item shall be considered.

-		since and only remaining treatment and accommendation			
31		P & F European type white glazed vitreous china 1st quality W.C pan (IS: 2556 Mark) with P or S trap including cutting and making good the wall and floor (item no. 1.3, sanitary installation work, PWD BSR) and P & F Low level Flushing Cistern of 10 litres			
	capacity (IS: 2556 mark) of approved make with complete fittings C.I. brackets duly painted, brass ball	No.	5		
		cock with ball (IS: 1703 mark) complete including cutting and making good the wall.			
		PVC with PVC bend and superior internal fittings as per			
		IS: 7231	1		
		(item no. 1.20.3, sanitary installation work, PWD BSR)			

- 2. Item no. 36, plumbing pipes, in BOQ of construction of new academic block and Item no. 38, plumbing pipes, in BOQ of renovation of existing office block, following shall be considered to quote rates:
 - a. CPVC pipes and fittings (SDR-11) shall be considered in general for plumbing
 - b. PVC pipes (4kg/cm²) shall be considered in general for rain water, waste water stacks.
- 3. Item no. 36 & 51, BOQ of construction of new academic block and Item no. 38 & 53, BOQ of renovation of existing office block, following shall be considered to quote rates:
 - a. Per meter rate basis for (lump sum rate items for plumbing piping & fitting and electrical conduiting & wiring) possible pipes, fittings, conduits and wiring shall be quoted by bidders and the same shall be attached with financial bid.